



PROPOSED LEGEND

⊙	PRO. MAN HOLE		PRO. DRIVEWAY APRON
⊕	PRO. SIGN		PRO. 6" SIDEWALK
⊖	PRO. GRADE		PRO. HANDICAP RAMPS
Ⓐ	REPLACE 4" TOP SOIL INSTALL SOD		REMOVE TREE
Ⓑ	4" SIDEWALK - 5' WIDE W/ BASE		
Ⓒ	CONCRETE DRIVE APRON AND THICKENED WALK SECTION		
Ⓓ	CARRIAGE WALK TYP. MATCH EXISTING		
Ⓔ	ADA COMPLIANT RAMP WITH TRUNCATED DOME PANELS CUT TO FIT AS REQUIRED.		

- NOTES:**
1. ALL SHOWN SLOPES ON DRIVES ARE SHOWN FOR REFERENCE. CONTRACTOR TO VERIFY SLOPES BEFORE INSTALLATION OF SIDEWALK. SHOWN SLOPES ARE FROM THE FRONT OF THE PROPOSED WALK TO THE FLOW LINE OF THE CURB AND DOES NOT TAKE INTO ACCOUNT THE HEIGHT OF THE DEPRESSED CURB. MAXIMUM SLOPE OF DRIVE APRONS SHALL BE 10% UNLESS APPROVED BY THE FIELD ENGINEER.
 2. DEPRESSED CURB SHALL BE INSTALLED IN FRONT OF ALL DRIVES.
 3. FRONT YARD SHALL POSITIVELY DRAIN OVER WALK AND PARKWAY AND CURB INTO GUTTER.
- E1.- PROVIDE INLET FILTER PROTECTION CONSISTING OF INLET FILTER BASKET AND STONE BAG CURB INLET PROTECTION AS DETAILED ON SHEET 29 OF THE PLANS AND DETAILED IN THE SWPPP. PROTECTION SHALL BE PROVIDED ON ALL INSTALLED AND EXISTING INLETS WITH IN THE PROJECT AREA AND ALL DOWN STREAM STRUCTURES AND ADDITIONALLY AROUND ALL STOCKPILES.
- E2.- PROVIDE CONCRETE WASHOUT CONTAINMENT BASIN AT LOCATIONS ACCESSIBLE TO CONCRETE TRUCKS AND WITH MINIMAL INTERFERENCE WITH TRAFFIC. CONTRACTOR TO CONSTRUCT BASINS PRIOR TO DELIVERY OF CONCRETE. BASIN SHALL BE REGULARLY CLEANED AND CONCRETE PROPERLY DISPOSED OF.

